

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2280-1453:100 Page 1 of 1

CATEGORY: Coating Materials

LISTEE: Station 1 Anti-Flame, 8581 Santa Monica Blvd., Los Angeles, CA 90069
Contact: Christine Knipe (805) 496-8484*

DESIGN: "Station 1 Anti-Flame" Type 2075W and 2075PW coating materials. Type 2075W shall be spray applied on tongue & groove Douglas Fir at a rate of 165 sq.ft/gal. and Type 2075PW shall be spray applied on 5/8" CDX plywood at a rate of 90 sq.ft/gal. Refer to listee's data sheet for additional detailed product description and instructions.

RATING:	Type 2075W applied to	<u>Flame Spread</u>	<u>Smoke Density</u>
	Tongue & Groove		
	Douglas Fir	20	150
	Type 2075PW applied to		
	5/8" CDX Plywood	10	45

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product identification and WHI label.

APPROVAL: Listed as coating material that will provide a "Class A Flame Spread" when applied on Douglas Fir or CDX plywood as described under "Design". For interior use only.

*Rev. 06-18-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager